



TESTING LABORATORY

T&T LABORATORY



REPORT OF TESTING

Serial No. : 11/MCI.AHV/IV/ 25

Date of Received : 12/09/2025 : Date of Test : 13/09/2025 Page : 1 of 1

Product & Type : HWPW-VC Film Face

Quantity/Size/ Thickness : 1 Pcs /200mm x 200mm /18.0mm (13 Plies)

Description/Condition of Sample : Wrapped by Plastic

Tested for : Film Face Plywood

Standard Test Method : EN 438-2:2016 High-pressure decorative laminates (HPL) -Part 2 Determination of properties

Company : KOSMEX COMPANY LIMITED

Address : No 5, Lane 205/37/26 Xuan Dinh Street, Xuan Dinh Ward, Bac Tu Liem District, Hanoi, Vietnam

Lot No. : Sample

Sample Supplier : Product Certification Dept. (HIEU)

Sampling Method : -

Sample Purpose : Daily testing

TEST RESULT:

Sample Code	Abrasion resistance
	Width 200 Length 200 / Rotation speed 60 rpm
18.0mm	Anti-slip surface (Rev.min)
	680

Place and date of issue, Ha Noi September 13, 2025



T.P NGUYỄN TIẾN THÀNH

This Certificate may not be reproduced Except in full, without written approval of the Company.

This Certificate refer to the tested sample only. All tests are carried out to the best of our knowledge and ability and our responsibility is limited to the correctness of the result. This certificate is issued on the understanding that it does not relieve parties concerned from their contractual obligation.