

REPORT OF TESTING

Serial No. : 23/MCI.AHA/I/ 25

Date of Received : 26 / 03 / 2025

Date of Test : 26 / 03 / 2025

Page : 1 of 1

Product & Type

: GLUE & MUF

Quantity/Size/Thickness

: 12.0mm (7Ply)

Description / Condition of Sample

: Wrapped by Plastic

Tested for

: Bending Strength

Standard Test Method

: JAS 0233-2 Structural Plywood

Company

: KOSMEX COMPANY LIMITED

Address

: No 5, Lane 205/37/26 Xuan Dinh Street, Xuan Dinh Ward, Bac Tu Liem District, Hanoi, Vietnam

Lot. No.

: Sample Plywood

Supplier Sample

: Product Certification Dept. (HIEU)

Sampling Method

: -

Sample Purpose

: Daily testing

TESTRESULT:

Sample Code	Bending Strength(MPa)	
	Width 50 Length 300	
12.0mm	Along	Across
	50.00	43.50

Place and date of issue, Ha Noi March 26, 2025



T.P NGUYỄN TIẾN THÀNH

This Certificate may not be reproduced Except in full, without written approval of the Company.

This Certificate refer to the tested sample only. All tests are carried out to the best of our knowledge and ability and our responsibility is limited to the correctness of the result. This certificate is issued on the understanding that it does not relieve parties concerned from their contractual obligation.